



Registrazione numero/Registration number

PED/0497/1879/10

CERTIFICATO DI CONFORMITÀ UE **EU CERTIFICATE OF CONFORMITY**

Visto il Manuale Qualità/Referring to the Quality Manual
Ed. n° 7 Rev. 01 del/dated 13/04/2021

si certifica che la Società/we certify that the Company

MADAS S.r.l.

Sede legale e Unità operativa / Registered office and Place of business

Via Moratello Z.A.I. 5/6/7 – 37048 San Pietro di Legnago (VR) – ITALY

ha implementato e mantiene un controllo finale sul prodotto conforme all'Allegato I e alla procedura del Modulo D1, Allegato III della Direttiva 2014/68/UE, allo scopo di produrre e testare
has implemented and maintains a final control on the product in compliance with the Annex I and with the Procedures of Module D1, Annex III of the 2014/68/EU Directive, for manufacturing and testing

ELETROVALVOLA NORMALMENTE APERTA TIPO **TYPE NORMALLY OPEN SOLENOID VALVE**

**Tipo/Type: EVAP-1-3-6/NA - EVA-1-3-6/NA - XVAP-1-3-6/NA - XVA-1-3-6/NA
JVAP-1-3-6/NA - JVA-1-3-6/NA - LVAP-1-3-6/NA - LVA-1-3-6/NA**

Dis./Dwg. n° (E-X-J-L)VAP(02-03-04)0000; (E-X-J-L)VA(05-06-07)0000; (E-X-J-L)VA(32-40-50)0000
 PS_{min} 0 barg; PS_{max} 1, 3, 6 barg; TS_{min} -20 °C; TS_{max} +60 °C
 DN 15 – DN 20 – DN 25 – DN 32 – DN 40 – DN 50
 Gruppo Fluido/Fluid Group 1 - CATEGORIA/CATEGORY II

Il Fabbricante è autorizzato ad apporre sull'Attrezzatura in pressione di cui sopra,
 dopo la marcatura CE, il numero di identificazione dell'Organismo Notificato.
 The Manufacturer is authorized to provide the above pressure Equipment with the CE marking,
 followed by the Notified Body identification number.

21/12/2010	11/01/2023(*)	-----	20/12/2025
Prima emissione First issue	Rinnovo Renewal	Ultima emissione Latest issue	Scadenza Expiry

(*) Dal 21/12/2022 al 10/01/2023 il certificato non era in corso di validità
 From 21/12/2022 to 10/01/2023 the certificate was not valid



PRD N° 032B

Signature of EA, IAF and ILAC
Mutual Recognition Agreement

0497

Ing. P. Fumagalli
B. A. Product

pag. 1/1

GQ002 REV.00